



SECTION

* CROSS SLOPE OF SIDEWALK SHALL BE 1.5% (2.00% MAX AS-BUILT)

- NOTES:**
1. THICKNESS OF AB AND HMA TO BE DETERMINED BY SOIL TEST AT TIME OF GRADING OPERATIONS.
 2. MINIMUM PAVING THICKNESS PER SPECIFICATIONS SECTION 8.07 OF THIS ORDINANCE.
 3. CURB AND GUTTER TO BE TYPE "A-6" (STANDARD No. 200). 8" CURB IS NOT ALLOWED.

NOT TO SCALE

PREPARED UNDER THE SUPERVISION OF:

Mark Lancaster 11/30/22
 DIRECTOR OF TRANSPORTATION DATE
 MARK LANCASTER, P.E.

REVISION	DESCRIPTION	MARK	DATE	APPROVED



COUNTY OF RIVERSIDE

SECONDARY FRONTAGE ROAD (82' R/W)

STANDARD No. 108