

SECTION

* CROSS SLOPE OF SIDEWALK SHALL BE 1.5% (2.00% MAX AS-BUILT)

NOTES:

1. THICKNESS OF AB AND HMA TO BE DETERMINED BY SOIL TEST AT TIME OF GRADING OPERATIONS.
2. MINIMUM PAVING THICKNESS PER SPECIFICATIONS SECTION 8.07 OF THIS ORDINANCE.
3. CURB AND GUTTER TO BE TYPE "A-8" (STANDARD No. 201). 6" CURB IS NOT ALLOWED.
4. DISTANCE FROM SIDEWALK TO RW, AND TO FLOWLINE, VARIES. SEE STANDARD No. 404 FOR DETAILS OF MEANDERING SIDEWALK.


NOT TO SCALE

PREPARED UNDER THE SUPERVISION OF:

Mark Lancaster

11/30/22
DATE

DIRECTOR OF TRANSPORTATION
MARK LANCASTER, P.E.



COUNTY OF RIVERSIDE

MAJOR FRONTAGE ROAD (97' R/W)

STANDARD No. 109

REVISION	DESCRIPTION	MARK	DATE	APPROVED