

MINIMUM CEMENTITIOUS MATERIAL CONTENT = 505 LB / CU YD

1.73 CU FT / LF

1 CU YD = 15.60 LF

NOTES:

1. RELATIVE COMPACTION OF SUBGRADE UNDER CURB AND GUTTER SHALL BE 95% MINIMUM.
2. WHEN ABUTTING SOIL HAS A HIGH SULFATE CONTENT, USE A MODIFIED CONCRETE MIX AND PLACE 6" MIN CLASS 2 AGGREGATE BASE AND 6 MIL PLASTIC SHEETING UNDER AND AROUND ALL SIDES OF CONCRETE IMPROVEMENTS. FOR EXPANSIVE SOIL, PLACE 6" MIN CLASS 2 AGGREGATE BASE UNDER CONCRETE IMPROVEMENTS AS DIRECTED BY THE ENGINEER. SEE SPECIFICATIONS SECTIONS 16.03 & 16.04 AND STANDARD No. 401 FOR REFERENCE.

NOT TO SCALE


PREPARED UNDER THE SUPERVISION OF:

Mark Lancaster

11/30/22

DIRECTOR OF TRANSPORTATION
MARK LANCASTER, P.E.

DATE



COUNTY OF RIVERSIDE

**TYPE A-8
CURB AND GUTTER
8" CURB FACE**

STANDARD No. 201

REVISION	DESCRIPTION	MARK	DATE	APPROVED