

MINIMUM CEMENTITIOUS MATERIAL CONTENT = 505 LB / CU YD


1.666 CU FT / LF
 1 CU YD = 16.21 LF

NOTES:

1. RELATIVE COMPACTION OF SUBGRADE UNDER CURB AND GUTTER SHALL BE 95% MINIMUM.
2. WHEN ABUTTING SOIL HAS A HIGH SULFATE CONTENT, USE A MODIFIED CONCRETE MIX AND PLACE 6" MIN CLASS 2 AGGREGATE BASE AND 6 MIL PLASTIC SHEETING UNDER AND AROUND ALL SIDES OF CONCRETE IMPROVEMENTS. FOR EXPANSIVE SOIL, PLACE 6" MIN CLASS 2 AGGREGATE BASE UNDER CONCRETE IMPROVEMENTS AS DIRECTED BY THE ENGINEER. SEE SPECIFICATIONS SECTIONS 16.03 & 16.04 AND STANDARD No. 401 FOR REFERENCE.

NOT TO SCALE

PREPARED UNDER THE SUPERVISION OF:			
<i>Mark Lancaster</i>			11/30/22
DIRECTOR OF TRANSPORTATION			DATE
MARK LANCASTER, P.E.			
REVISION	DESCRIPTION	MARK	APPROVED



COUNTY OF RIVERSIDE

**TYPE "W" CURB
 WEDGE CURB**

STANDARD No. 202A