

NOTES:

1. INSTALL PER LOCAL WATER DISTRICT STANDARD DETAIL.
2. INSTALL WYE STRAINER AND/OR PRESSURE REGULATOR IF SPECIFIED AND ALLOWED.
3. CONCRETE PAD LENGTH AND WIDTH SHALL BE 6" GREATER THAN SIZE OF BACKFLOW CAGE. CONCRETE MINIMUM CEMENTITIOUS MATERIAL CONTENT = 505 LB / CU YD.
4. VIT QUICKPAD IS ALLOWED. BACKFLOW CAGE SHALL BE STAINLESS STEEL OR ALUMINUM BY VIT.
5. FOR USE IN AREAS WITHOUT SEPARATE APPROVED LANDSCAPE PLANS.


NOT TO SCALE

PREPARED UNDER THE SUPERVISION OF:

Mark Lancaster

11/30/22
DATE

DIRECTOR OF TRANSPORTATION
MARK LANCASTER, P.E.



COUNTY OF RIVERSIDE

**BACKFLOW PREVENTION
DEVICE INSTALLATION**

STANDARD No. 1103

REVISION	DESCRIPTION	MARK	DATE	APPROVED